IEC 61850 Certificate - IEC 61850 Certificate #2906

P40 Agile P545 Line Differential Protect [GE Renewable Energy]

07/08/2021 04:58 PM - Herbert Falk

Status:	Approved		
Priority:	Normal		
61850 Edition:	Edition 2	**Certificate Name:**	10175300-INC 19-3210
61850 Tested Aspects:	Server	**Certificate Hash:**	323AE4BF0D64B009C7AF2F12FB2081646EBF0352C5BE833E9DEDC868B09295CC
Company:	GE Renewable Energy	**Vendor Artifact File Name:**	
Address:	St. Leonards Building, Harry Kerr Drive Stafford, UK, ST16 1 WT	**Vendor Artifact Hash:**	
Product:	P40 Agile P545 Line Differential Protect	**Umbrella Organization:**	
HW Version:	M	**Optional Reservation Test:**	No
SW Version:	92A	**Serial Number:**	
Key Words:	Distance, Protection, Relay	**Publisher Legacy Variants:**	
Test Procedure Version:	1.0	**Publisher Preferred Rates:**	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	**Publisher Preferred Variants:**	
Certificate/Result Reviewer:	bruce.muschlitz	**Subscriber Legacy Variants:**	
Approval Date:	01/08/2020	**Subscriber Preferred Variants:**	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	**Subscriber Preferred Rates:**	
Current Test Lab Name:	DNV Netherlands (A)	**Product Variants:**	
Test Document:			

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:58 PM - Herbert Falk

- File 19-3210_DNVGL_GE_MiCOM_P545_P543_P443_ServerEd2_Certificate.pdf added

Files

19-3210_DNVGL_GE_MiCOM_P545_P543_P443_ServerEd2_Certificate.pdf	116 kB	07/08/2021	Herbert Falk