

IEC 61850 Certificate - IEC 61850 Certificate #2906

P40 Agile P545 Line Differential Protect [GE Renewable Energy]

07/08/2021 04:58 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	10175300-INC 19-3210
61850 Edition:	Edition 2	Certificate Hash:	323AE4BF0D64B009C7AF2F12FB2081 646EBF0352C5BE833E9DEDC868B092 95CC
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	GE Renewable Energy	Vendor Artifact Hash:	
Address:	St. Leonards Building, Harry Kerr Drive Stafford, UK, ST16 1 WT	Umbrella Organization:	
Product:	P40 Agile P545 Line Differential Protect	Optional Reservation Test:	No
HW Version:	M	Serial Number:	
SW Version:	92A	Publisher Legacy Variants:	
Key Words:	Distance, Protection, Relay	Publisher Preferred Rates:	
Test Procedure Version:	1.0	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Preferred Variants:	
Approval Date:	01/08/2020	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:58 PM - Herbert Falk

- File 19-3210_DNVGL_GE_MiCOM_P545_P543_P443_ServerEd2_Certificate.pdf added

Files

19-3210_DNVGL_GE_MiCOM_P545_P543_P443_ServerEd2_Certificate.pdf	16 KB	07/08/2021	Herbert Falk
---	-------	------------	--------------