

IEC 61850 Certificate - IEC 61850 Certificate #2907

CSC-326-EB Transformer Protection IED [Beijing Sifang Automation Co., Ltd.]

07/08/2021 04:58 PM - Herbert Falk

Status:	Approved	
Priority:	Normal	
61850 Edition:	Edition 2	Certificate Name: 10160572-INC 19-2945
61850 Tested Aspects:	Server	Certificate Hash: 42239427E40B6377870AE1CDDE3430 CCC958D31EE8CDBFB2CB66C0761B8E04F5
Company:	Beijing Sifang Automation Co., Ltd.	Vendor Artifact File Name:
Address:	No.9, Shangdi Fourth Street Haidian District Beijing 100085 Peoples Republic of China	Vendor Artifact Hash:
Product:	CSC-326-EB Transformer Protection IED	Umbrella Organization:
HW Version:	8SF.004.520/V2	Optional Reservation Test: No
SW Version:	V1.41	Serial Number:
Key Words:	Differential, Protection, Relay	Publisher Legacy Variants:
Test Procedure Version:	2.0_rev1	Publisher Preferred Rates:
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Service Tracking (B15), Setting Group (B4), Setting Group Definition (B4+), Substitution (B3), Time Synchronization (B13), Unbuffered Reporting (B5)	Publisher Preferred Variants:
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Legacy Variants:
Approval Date:	01/16/2020	Subscriber Preferred Variants:
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	Subscriber Preferred Rates:
Current Test Lab Name:	DNV Netherlands (A)	Product Variants:
Test Document:		Time Activated Control:
Description This certificate and its information was migrated from a previous database		

History

#1 - 07/08/2021 04:58 PM - Herbert Falk

- File 19-2945_DNVGL_Sifang_CSC-326-EB_ServerEd2_Certificate.pdf added

Files

19-2945_DNVGL_Sifang_CSC-326-EB_ServerEd2_Certificate.pdf	116 KB	07/08/2021	Herbert Falk
---	--------	------------	--------------