

IEC 61850 Certificate - IEC 61850 Certificate #2909

YSCM-1900 Integration Control Monitoring [YOUSUNG Instrument & Electric Co., Ltd.]

07/08/2021 04:58 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	19-059842-01-5
61850 Edition:	Edition 1	Certificate Hash:	087916FA7F456CA054B31870A9BA581 3B53B9394F81F1415AE7858CF6E2129 5D
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	YOUSUNG Instrument & Electric Co., Ltd.	Vendor Artifact Hash:	
Address:	76, Gaetbeol-ro (Songdo-dong), Yeonsu-gu, Incheon, Republic of Korea, 21999	Umbrella Organization:	
Product:	YSCM-1900 Integration Control Monitoring	Optional Reservation Test:	No
HW Version:	OS: Linux	Serial Number:	
SW Version:	1.0	Publisher Legacy Variants:	
Key Words:	Protection, Relay	Publisher Preferred Rates:	
Test Procedure Version:	3.2	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Preferred Variants:	
Approval Date:	01/28/2020	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	Korea Testing Laboratory (A)		
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:58 PM - Herbert Falk

- File 19-059842-01-5_YOUSUNG_YSCM-1900_Server_Ed1_Certification_KTL.pdf added

Files

19-059842-01-5_YOUSUNG_YSCM-1900_Server_Ed1_Certification_KTL.pdf	07/08/2021	Herbert Falk
---	------------	--------------