

IEC 61850 Certificate - IEC 61850 Certificate #2911

Argos-IEC61850 Client Smart Digital Proc [ENTEC Electric & Electronic Co., Ltd.]

07/08/2021 04:58 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	19-079949-01-1
61850 Edition:	Edition 1	Certificate Hash:	0CAE9AA75E348038716A3AFBE2CAC BF20BFFC627AFB36DBB84F6E0205B A2DA5D
61850 Tested Aspects:	Client	Vendor Artifact File Name:	
Company:	ENTEC Electric & Electronic Co., Ltd.	Vendor Artifact Hash:	
Address:	225-38 Choirubaek-ro, Bongdam-eup, Hwasung-si, Gyeonggi-do, Republic of Korea, 18329	Umbrella Organization:	
Product:	Argos-IEC61850 Client Smart Digital Proc	Optional Reservation Test:	No
HW Version:	OS : Linux	Serial Number:	
SW Version:	1.0	Publisher Legacy Variants:	
Key Words:	Comm	Publisher Preferred Rates:	
Test Procedure Version:	1.1	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), SBO Control (12b), Setting Group (B4), Setting Group Definition (B4+), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Preferred Variants:	
Approval Date:	02/06/2020	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	Korea Testing Laboratory (A)		
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:58 PM - Herbert Falk

- File 19-079949-01-1_ENTEC_SDP_Client_Ed1_Certification_KTL.pdf added

Files

19-079949-01-1_ENTEC_SDP_Client_Ed1_Certification_KTL.pdf	115 KB	07/08/2021	Herbert Falk
---	--------	------------	--------------