

IEC 61850 Certificate - IEC 61850 Certificate #2914

MiCOM AGILE P645 TRANSFORMER PROTECTION [M/s. GE T&D India Ltd.]

07/08/2021 04:58 PM - Herbert Falk

| | | | |
|--|---|---------------------------------------|--|
| Status: | Approved | Test Document: | |
| Priority: | Normal | Certificate Name: | CPRIBLRMUADSASL20TC0002 |
| 61850 Edition: | Edition 2 | Certificate Hash: | 09BB97A1F893BD5EE0F63B667BC491 A65356E30E10CC246562F241E9F9DC 9382 |
| 61850 Tested Aspects: | Server | Vendor Artifact File Name: | |
| Company: | M/s. GE T&D India Ltd. | Vendor Artifact Hash: | |
| Address: | 19/1, G.S.T. ROAD, PALLAVARAM, CHENNAI - 600043 INDIA | Umbrella Organization: | |
| Product: | MiCOM AGILE P645 TRANSFORMER PROTECTION | Optional Reservation Test: | No |
| HW Version: | P645-P | Serial Number: | |
| SW Version: | 22 | Publisher Legacy Variants: | |
| Key Words: | Differential, Protection, Relay | Publisher Preferred Rates: | |
| Test Procedure Version: | 1.0 | Publisher Preferred Variants: | |
| IEC 61850 Blocks Certified: | Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5) | Subscriber Legacy Variants: | |
| Certificate/Result Reviewer: | bruce.muschlitz | Subscriber Preferred Variants: | |
| Approval Date: | 02/14/2020 | Subscriber Preferred Rates: | |
| Standards Tested: | 61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1 | | |
| Current Test Lab Name: | Central Power Research Institute India (A) | | |
| Description | | | |
| This certificate and its information was migrated from a previous database | | | |

History

#1 - 07/08/2021 04:58 PM - Herbert Falk

- File CPRI - GE TandD INDIA LTD - P645 - CPRIBLRMUADSASL20TC0002.pdf added

Files

CPRI - GE TandD INDIA LTD - P645 - CPRIBLRMUADSASL20TC0002.pdf 1MB

07/08/2021

Herbert Falk