

IEC 61850 Certificate - IEC 61850 Certificate #2917

Reyrolle 7SR511 Overcurrent and feeder p [Siemens AG]

07/08/2021 04:59 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	10175470-INC 20-2229
61850 Edition:	Edition 2	Certificate Hash:	FF8DA3A9FEB226D90FBF78EC35A9D 5BC8980F4B54EC6C4A874D75CD74A 871314
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Siemens AG	Vendor Artifact Hash:	
Address:	Humboldtstrasse 59 90459 Nuremberg Germany	Umbrella Organization:	
Product:	Reyrolle 7SR511 Overcurrent and feeder p	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	V01.11.00	Publisher Legacy Variants:	
Key Words:	IOC, Protection, Relay, TOC	Publisher Preferred Rates:	
Test Procedure Version:	2.0_rev2	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Preferred Variants:	
Approval Date:	03/10/2020	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:59 PM - Herbert Falk

- File 20-2229_DNVGL_Siemens_7SR511_7SR542_7SR543_ServerEd2_Certificate.pdf added

Files

20-2229_DNVGL_Siemens_7SR511_7SR542_7SR543_ServerEd2_Certificate.pdf 07/08/2021

Herbert Falk