IEC 61850 Certificate - IEC 61850 Certificate #2917

Reyrolle 7SR511 Overcurrent and feeder p [Siemens AG]

07/08/2021 04:59 PM - Herbert Falk

Status:	Approved		
Priority:	Normal		
61850 Edition:	Edition 2	**Certificate Name:**	10175470-INC 20-2229
61850 Tested Aspects:	Server	**Certificate Hash:**	FF8DA3A9FEB226D90FBF78EC35A9D5BC8980F4B54EC6C4A874D75CD74A871314
Company:	Siemens AG	**Vendor Artifact File Name:**	
Address:	Humboldtstrasse 59 90459 Nuremberg Germany	**Vendor Artifact Hash:**	
Product:	Reyrolle 7SR511 Overcurrent and feeder p	**Umbrella Organization:**	
HW Version:		**Optional Reservation Test:**	No
SW Version:	V01.11.00	**Serial Number:**	
Key Words:	IOC, Protection, Relay, TOC	**Publisher Legacy Variants:**	
Test Procedure Version:	2.0_rev2	**Publisher Preferred Rates:**	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	**Publisher Preferred Variants:**	
Certificate/Result Reviewer:	bruce.muschlitz	**Subscriber Legacy Variants:**	
Approval Date:	03/10/2020	**Subscriber Preferred Variants:**	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	**Subscriber Preferred Rates:**	
Current Test Lab Name:	DNV Netherlands (A)	**Product Variants:**	
Test Document:			

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:59 PM - Herbert Falk

- File 20-2229_DNVGL_Siemens_7SR511_7SR542_7SR543_ServerEd2_Certificate.pdf added

Files

20-2229_DNVGL_Siemens_7SR511_7SR542_7SR543_ServerEd2_Certificate.pdf	115 kB	07/08/2021	Herbert Falk