

IEC 61850 Certificate - IEC 61850 Certificate #2919

Protective Relay (SBP-K110) [Sanion Co., Ltd.]

07/08/2021 04:59 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	20TC200200
61850 Edition:	Edition 1	Certificate Hash:	2D22CAE9C4F4F724B6386173B9D3B1 E4901AF339A641DB60E9338F58E5964 075
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Sanion Co., Ltd.	Vendor Artifact Hash:	
Address:	13, Geomdan-ro, 114beon-gil, Seo-gu, Incheon, Republic of Korea, 22663	Umbrella Organization:	
Product:	Protective Relay (SBP-K110)	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	MPU:1.50;LDSP;1.50;MDSP:1.10;1.0	Publisher Legacy Variants:	
Key Words:	Protection	Publisher Preferred Rates:	
Test Procedure Version:	3.3a	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Preferred Variants:	
Approval Date:	03/27/2020	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	Korea Electrotechnology Research Institute (A)		

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:59 PM - Herbert Falk

- File 20TC200200_Sanion_SBP-K110_Server_Ed1_KERI.pdf added

Files

20TC200200_Sanion_SBP-K110_Server_Ed1_KERI.pdf	347 KB	07/08/2021	Herbert Falk
--	--------	------------	--------------