

IEC 61850 Certificate - IEC 61850 Certificate #2925

SPRECON-E-C Protection and Control Unit [ALFANAR Electrical Systems]

07/08/2021 04:59 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	10200769-INC 20-2142
61850 Edition:	Edition 2	Certificate Hash:	DD8D594C3EBCCC8FA2E13F6FD6E48 EE09DA0CF08A11E24527CABF2815B4 3CE50
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	ALFANAR Electrical Systems	Vendor Artifact Hash:	
Address:	ALFANAR Industrial City New Al Kharj Road, Riyadh Kingdom of Saudi Arabia	Umbrella Organization:	
Product:	SPRECON-E-C Protection and Control Unit	Optional Reservation Test:	No
HW Version:	210.054/G013	Serial Number:	
SW Version:	8.66	Publisher Legacy Variants:	
Key Words:	RTU	Publisher Preferred Rates:	
Test Procedure Version:	2.0_rev2	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Service Tracking (B15), Setting Group (B4), Setting Group Definition (B4+), Substitution (B3), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Preferred Variants:	
Approval Date:	05/08/2020	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 04:59 PM - Herbert Falk

- File 20-2142_DNVGL_Alfanar_SPRECON-E-C_ServerEd2_Certificate.pdf added

Files

20-2142_DNVGL_Alfanar_SPRECON-E-C_ServerEd2_Certificate.pdf 120 KB

07/08/2021

Herbert Falk