

IEC 61850 Certificate - IEC 61850 Certificate #2933

MiCOM Agile P743 Busbar Protection [GE Renewable Energy]

07/08/2021 04:59 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	50745.6743.802
61850 Edition:	Edition 2	Certificate Hash:	470E0FA310AA1A6D4B846C29610C34 A99C51EB5F406317B4C1FA02FEBB12 DAC6
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	GE Renewable Energy	Vendor Artifact Hash:	
Address:	St. Leonards Building, Redhill Business Park Stafford, UK, ST16 1WT	Umbrella Organization:	
Product:	MiCOM Agile P743 Busbar Protection	Optional Reservation Test:	No
HW Version:	K	Serial Number:	
SW Version:	70B	Publisher Legacy Variants:	
Key Words:	Differential, Protection, Relay	Publisher Preferred Rates:	
Test Procedure Version:	2.0_rev3	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Preferred Variants:	
Approval Date:	06/30/2020	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	Grid Automation Laboratories (B)		

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:59 PM - Herbert Falk

- File 50745.6743.802_GE_P743_P741_V70B_Edition2_Certificate.pdf added

#2 - 08/04/2021 09:38 AM - Herbert Falk

- Current Test Lab Name changed from UK Grid Solutions Ltd (B) to Grid Automation Laboratories (B)

Files

50745.6743.802_GE_P743_P741_V70B_Edition2_Certificate.pdf	277 KB	07/08/2021	Herbert Falk
---	--------	------------	--------------