

IEC 61850 Certificate - IEC 61850 Certificate #2934

UR N60 Network Stability and Synchrophas [GE Renewable Energy]

07/08/2021 04:59 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	50745.6UR.805
61850 Edition:	Edition 2	Certificate Hash:	AD96C5A228224D526A90E2B0A9EDC 36C285B95993BA6AB57F444162AB885 36A5
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	GE Renewable Energy	Vendor Artifact Hash:	
Address:	650 Markland St. Markham, ON L6C 0M1, Canada	Umbrella Organization:	
Product:	UR N60 Network Stability and Synchrophas	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	8.02	Publisher Legacy Variants:	
Key Words:	Measurement, Protection, Relay	Publisher Preferred Rates:	
Test Procedure Version:	2.0_rev3	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Preferred Variants:	
Approval Date:	06/30/2020	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	Grid Automation Laboratories (B)		

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:59 PM - Herbert Falk

- File 50745.6UR.805_GE_UR_V8.02_Edition2_Certificate.pdf added

#2 - 08/04/2021 09:38 AM - Herbert Falk

- Current Test Lab Name changed from UK Grid Solutions Ltd (B) to Grid Automation Laboratories (B)

Files

50745.6UR.805_GE_UR_V8.02_Edition2_Certificate.pdf	292 KB	07/08/2021	Herbert Falk
--	--------	------------	--------------