

IEC 61850 Certificate - IEC 61850 Certificate #2938

SMD-K020 Substation Automation Informatio [Sanion Co., Ltd.]

07/08/2021 04:59 PM - Herbert Falk

Status:	Approved	
Priority:	Normal	
61850 Edition:	Edition 1	Certificate Name: 20-015458-03-5
61850 Tested Aspects:	Server	Certificate Hash: F583482C0535754E9391FEB3C6B073A23829961A6A2FF45B71C596CB9E38E7B1
Company:	Sanion Co., Ltd.	Vendor Artifact File Name:
Address:	13, Geomdan-ro, 114beon-gil, Seo-gu, Incheon, Republic of Korea, 22663	Vendor Artifact Hash:
Product:	SMD-K020 Substation Automation Informatio	Umbrella Organization:
HW Version:	SMD-K020 with WindowsServer 2016	Optional Reservation Test: No
SW Version:	1.0	Serial Number:
Key Words:	Comm	Publisher Legacy Variants:
Test Procedure Version:	3.2	Publisher Preferred Rates:
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), Time Synchronization (B13), Unbuffered Reporting (B5)	Publisher Preferred Variants:
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Legacy Variants:
Approval Date:	07/28/2020	Subscriber Preferred Variants:
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	Subscriber Preferred Rates:
Current Test Lab Name:	Korea Testing Laboratory (A)	Product Variants:
Test Document:		Time Activated Control:
Description This certificate and its information was migrated from a previous database		

History

#1 - 07/08/2021 04:59 PM - Herbert Falk

- File 20-015458-03-5_SANION_SMD-K020_Server_Ed1_Certification_KTL added

#2 - 07/11/2021 11:05 AM - Herbert Falk

- File 20-015458-03-5_SANION_SMD-K020_Server_Ed1_Certification_KTL.pdf added

- Address updated

#3 - 07/11/2021 11:05 AM - Herbert Falk

- File deleted (20-015458-03-5_SANION_SMD-K020_Server_Ed1_Certification_KTL)

Files

20-015458-03-5_SANION_SMD-K020_Server_Ed1_Certification_KTL.pdf	619 KB	07/11/2021	Herbert Falk
---	--------	------------	--------------