

IEC 61850 Certificate - IEC 61850 Certificate #2941

ECU-4784 Substation Automation Informati [Sanion Co., Ltd.]

07/08/2021 04:59 PM - Herbert Falk

Status:	Approved	
Priority:	Normal	
61850 Edition:	Edition 1	Certificate Name: 20-015458-02-5
61850 Tested Aspects:	Client	Certificate Hash: 1F9EB7C51925C2A1E8C978E3196839 CF512A8741A2831820D0402061E7912 C5B
Company:	Sanion Co., Ltd.	Vendor Artifact File Name:
Address:	13, Geomdan-ro, 114beon-gil, Seo-gu, Incheon, Republic of Korea, 22663	Vendor Artifact Hash:
Product:	ECU-4784 Substation Automation Informati	Umbrella Organization:
HW Version:	ADVANTEC ECU-4784	Optional Reservation Test: No
SW Version:	1.0	Serial Number:
Key Words:	Comm, RTU	Publisher Legacy Variants:
Test Procedure Version:	1.1	Publisher Preferred Rates:
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), SBO Control (12b), Setting Group (B4), Setting Group Definition (B4+), Time Synchronization (B13), Unbuffered Reporting (B5)	Publisher Preferred Variants:
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Legacy Variants:
Approval Date:	07/29/2020	Subscriber Preferred Variants:
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	Subscriber Preferred Rates:
Current Test Lab Name:	Korea Testing Laboratory (A)	Product Variants:
Test Document:		Time Activated Control:
Description This certificate and its information was migrated from a previous database		

History

#1 - 07/08/2021 04:59 PM - Herbert Falk

- File 20-015458-02-5_SANION_ECU-4784_Client_Ed1_Certification_KTL.pdf added

Files

20-015458-02-5_SANION_ECU-4784_Client_Ed1_Certification_KTL.pdf	11.4 KB	07/08/2021	Herbert Falk
---	---------	------------	--------------