

# IEC 61850 Certificate - IEC 61850 Certificate #2943

## DS Agile C264 BAY CONTROL UNIT [M/s. GE T&D India Ltd.]

07/08/2021 04:59 PM - Herbert Falk

<b>Status:</b>	Approved	<b>Test Document:</b>	
<b>Priority:</b>	Normal	<b>Certificate Name:</b>	CPRIBLRMUADSASL20TC0003
<b>61850 Edition:</b>	Edition 2	<b>Certificate Hash:</b>	C54B863D35F17923BCF707795E61597 FEEF42AA2E413E6165E987912EDD19 B64
<b>61850 Tested Aspects:</b>	Server	<b>Vendor Artifact File Name:</b>	
<b>Company:</b>	M/s. GE T&D India Ltd.	<b>Vendor Artifact Hash:</b>	
<b>Address:</b>	19/1, G.S.T. ROAD, PALLAVARAM, CHENNAI - 600043 INDIA	<b>Umbrella Organization:</b>	
<b>Product:</b>	DS Agile C264 BAY CONTROL UNIT	<b>Optional Reservation Test:</b>	No
<b>HW Version:</b>	CPUv4	<b>Serial Number:</b>	
<b>SW Version:</b>	DS Agile 7.6.1.2-base	<b>Publisher Legacy Variants:</b>	
<b>Key Words:</b>	Bay Controller	<b>Publisher Preferred Rates:</b>	
<b>Test Procedure Version:</b>	1.0	<b>Publisher Preferred Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Substitution (B3), Time Synchronization (B13), Unbuffered Reporting (B5)	<b>Subscriber Legacy Variants:</b>	
<b>Certificate/Result Reviewer:</b>	bruce.muschlitz	<b>Subscriber Preferred Variants:</b>	
<b>Approval Date:</b>	08/07/2020	<b>Subscriber Preferred Rates:</b>	
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	Central Power Research Institute India (A)		

### Description

This certificate and its information was migrated from a previous database

### History

#1 - 07/08/2021 04:59 PM - Herbert Falk

- File CPRI - GE TandD INDIA LTD - C264 - CPRIBLRMUADSASL20TC0003.pdf added

### Files

CPRI - GE TandD INDIA LTD - C264 - CPRIBLRMUADSASL20TC0003.pdf 2.17 MB

07/08/2021

Herbert Falk