

IEC 61850 Certificate - IEC 61850 Certificate #2946

SA-LID Substation Automation Local Inform [GENAD SYSTEM Co.]

07/08/2021 04:59 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	20-008135-03-5
61850 Edition:	Edition 1	Certificate Hash:	3B80A20A52BA1D5FC0593E7AB7B71D CC429F11E1C7E59F20C1DD2E59A732 5110
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	GENAD SYSTEM Co.	Vendor Artifact Hash:	
Address:	78, Hyeoksinsandan 5-gil, Naju-si, Jeollanam-do, Republic of Korea	Umbrella Organization:	
Product:	SA-LID Substation Automation Local Inform	Optional Reservation Test:	No
HW Version:	ADVANTEC ECU-4784, WinSrv 2012R2	Serial Number:	
SW Version:	1.0	Publisher Legacy Variants:	
Key Words:	Bay Controller	Publisher Preferred Rates:	
Test Procedure Version:	3.3	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Preferred Variants:	
Approval Date:	08/19/2020	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	Korea Testing Laboratory (A)		

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 04:59 PM - Herbert Falk

- File 20-008135-03-5_Genad_Server_Ed1_Certification_KTL.pdf added

Files

20-008135-03-5_Genad_Server_Ed1_Certification_KTL.pdf	62.2 KB	07/08/2021	Herbert Falk
---	---------	------------	--------------