

# IEC 61850 Certificate - IEC 61850 Certificate #2947

## K-SDP Smart Control and Data Acquisition [KOOSSTECH. Inc.]

07/08/2021 05:00 PM - Herbert Falk

<b>Status:</b>	Approved	<b>Test Document:</b>	
<b>Priority:</b>	Normal	<b>Certificate Name:</b>	20TC200693
<b>61850 Edition:</b>	Edition 1	<b>Certificate Hash:</b>	5E88067944EEB9CAFDA42CD02AE7E 5E55617B147369DA4167B45D3AC821 EBEA4
<b>61850 Tested Aspects:</b>	Client	<b>Vendor Artifact File Name:</b>	
<b>Company:</b>	KOOSSTECH. Inc.	<b>Vendor Artifact Hash:</b>	
<b>Address:</b>	14, Gasan digital 2-ro, Geumcheon-gu, Seoul, Republic of Korea	<b>Umbrella Organization:</b>	
<b>Product:</b>	K-SDP Smart Control and Data Acquisition	<b>Optional Reservation Test:</b>	No
<b>HW Version:</b>		<b>Serial Number:</b>	
<b>SW Version:</b>	SW: 1.0; FW: 1.0	<b>Publisher Legacy Variants:</b>	
<b>Key Words:</b>	Comm, RTU	<b>Publisher Preferred Rates:</b>	
<b>Test Procedure Version:</b>	1.1	<b>Publisher Preferred Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), SBO Control (12b), Setting Group (B4), Setting Group Definition (B4+), Time Synchronization (B13), Unbuffered Reporting (B5)	<b>Subscriber Legacy Variants:</b>	
<b>Certificate/Result Reviewer:</b>	bruce.muschlitz	<b>Subscriber Preferred Variants:</b>	
<b>Approval Date:</b>	08/21/2020	<b>Subscriber Preferred Rates:</b>	
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	Korea Electrotechnology Research Institute (A)		
<b>Description</b>			
This certificate and its information was migrated from a previous database			

### History

#1 - 07/08/2021 05:00 PM - Herbert Falk

- File 20TC00693\_KOOSSTECH\_K-SDP\_Client\_Ed1\_KERI.pdf added

### Files

20TC00693_KOOSSTECH_K-SDP_Client_Ed1_KERI.pdf	366 KB	07/08/2021	Herbert Falk
---	--------	------------	--------------