

IEC 61850 Certificate - IEC 61850 Certificate #2948

DAONSYs-MSA-SMD Substation Automation In [DAONSYs Limited Company]

07/08/2021 05:00 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	20-036046-01-5
61850 Edition:	Edition 1	Certificate Hash:	11CD56761AEC812F5DC7AAF137EB8 EB344F7E1CE00A7AD0B9303FBF64A6 5F028
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	DAONSYs Limited Company	Vendor Artifact Hash:	
Address:	Daonsys Limited Company 32, Songdogwahak-ro, Yeonsu-gu, Incheon, Republic of Korea	Umbrella Organization:	
Product:	DAONSYs-MSA-SMD Substation Automation In	Optional Reservation Test:	No
HW Version:	YSSMD-7200 with WindServer2012R2	Serial Number:	
SW Version:	Substation Automation Informatio	Publisher Legacy Variants:	
Key Words:	RTU	Publisher Preferred Rates:	
Test Procedure Version:	3.3	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Preferred Variants:	
Approval Date:	09/02/2020	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	Korea Testing Laboratory (A)		
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 05:00 PM - Herbert Falk

- File 20-036046-01-5_Daonsys_DAONSYs-MSA-SMD_Server_Ed1_Certification_KTL.pd added

#2 - 07/11/2021 11:04 AM - Herbert Falk

- File 20-036046-01-5_Daonsys_DAONSYs-MSA-SMD_Server_Ed1_Certification_KTL.pdf added

- Address updated

#3 - 07/11/2021 11:04 AM - Herbert Falk

- File deleted (20-036046-01-5_Daonsys_DAONSYs-MSA-SMD_Server_Ed1_Certification_KTL.pd)

Files

20-036046-01-5_Daonsys_DAONSYS-MSA-SMD_Server_Ed1_Certification_KTL.pdf 07/11/2021

Herbert Falk