

IEC 61850 Certificate - IEC 61850 Certificate #2950

Substation Automation Local Information [HANSHIN ELECTRIC Co.,Ltd.]

07/08/2021 05:00 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	20-023220-03-4
61850 Edition:	Edition 1	Certificate Hash:	E2D4DE824F9A4CF7A4F65B5FD0F299 0ECFBB93FC1583E8022A6D8867FA56 4CB7
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	HANSHIN ELECTRIC Co.,Ltd.	Vendor Artifact Hash:	
Address:	42, Sanbon-ro 48beon-gil, Gunpo-si, Gyeonggi-do, Republic of Korea, 15846	Umbrella Organization:	
Product:	Substation Automation Local Information	Optional Reservation Test:	No
HW Version:	ADVANTEC ECU-4784 WinServe2012R2	Serial Number:	
SW Version:	2	Publisher Legacy Variants:	
Key Words:	Bay Controller, Comm	Publisher Preferred Rates:	
Test Procedure Version:	3.3	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Preferred Variants:	
Approval Date:	09/15/2020		
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	Korea Testing Laboratory (A)		

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 05:00 PM - Herbert Falk

- File 20-023220-03-4_Hansin_ECU-4784_Server_Ed1_Certification_KTL.pdf added

Files

20-023220-03-4_Hansin_ECU-4784_Server_Ed1_Certification_KTL.pdf 2.8 KB

07/08/2021

Herbert Falk