

IEC 61850 Certificate - IEC 61850 Certificate #2953

DCP3 Multifunctional Device for DC tract [Tianjin Keyvia Electric Co.Ltd.]

07/08/2021 05:00 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	D 103683 0002 Rev. 00
61850 Edition:	Edition 2	Certificate Hash:	85FB6569D0D80AFB2651C726731387 E6E3B0C42525B05C3DBD4727EC065 C5633
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Tianjin Keyvia Electric Co.Ltd.	Vendor Artifact Hash:	
Address:	No. 15 Haita iFazhanErlu Road, Huayuan Industrial Park (Outer Ring), Binhai Hi-tech Development District, 300392 Tianjin, P. R. China	Umbrella Organization:	
Product:	DCP3 Multifunctional Device for DC tract	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	2.0.1	Publisher Legacy Variants:	
Key Words:	Protection, Relay	Publisher Preferred Rates:	
Test Procedure Version:	2.0_rev5	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Setting Group (B4), Setting Group Definition (B4+), Substitution (B3), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Preferred Variants:	
Approval Date:	09/25/2020	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	TUV SUD China Ltd (A)		
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 05:00 PM - Herbert Falk

- File 20-D 103683 0002 Rev. 00-Keyvia_DCP3_IEC61850Ed2-Server-Certificate.pdf added

#2 - 07/11/2021 11:03 AM - Herbert Falk

- File 20-D 103683 0002 Rev. 00-Keyvia_DCP3_IEC61850Ed2-Server-Certificate.pdf added

- Address updated

#3 - 07/11/2021 11:03 AM - Herbert Falk

- File deleted (20-D 103683 0002 Rev. 00-Keyvia_DCP3_IEC61850Ed2-Server-Certificate.pdf)

Files

20-D 103683 0002 Rev. 00-Keyvia_DCP3_IEC61850Ed2-Server-Certificate.cer

07/11/2021

Herbert Falk