

# IEC 61850 Certificate - IEC 61850 Certificate #2955

## Acuvim IIW Power Meter with AXM-WEB2 [Accuenergy (Canada) Inc.]

07/08/2021 05:00 PM - Herbert Falk

<b>Status:</b>	Approved	<b>Test Document:</b>	
<b>Priority:</b>	Normal	<b>Certificate Name:</b>	10174007-INC 20-2752
<b>61850 Edition:</b>	Edition 2	<b>Certificate Hash:</b>	5DAF5C381BF16E23F7D224A89ACB4 D6DF775EFDE93B8B933AD8DFB6713 6F21CB
<b>61850 Tested Aspects:</b>	Server	<b>Vendor Artifact File Name:</b>	
<b>Company:</b>	Accuenergy (Canada) Inc.	<b>Vendor Artifact Hash:</b>	
<b>Address:</b>	700-2 Lansing Square Toronto ON M2J 4P8, Canada	<b>Umbrella Organization:</b>	
<b>Product:</b>	Acuvim IIW Power Meter with AXM-WEB2	<b>Optional Reservation Test:</b>	No
<b>HW Version:</b>		<b>Serial Number:</b>	
<b>SW Version:</b>	61850: v1.14; IIW-D-5A-P1: v3.69	<b>Publisher Legacy Variants:</b>	
<b>Key Words:</b>	Measurement	<b>Publisher Preferred Rates:</b>	
<b>Test Procedure Version:</b>	2.0.3	<b>Publisher Preferred Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Enhanced SBO Control (12d), Unbuffered Reporting (B5)	<b>Subscriber Legacy Variants:</b>	
<b>Certificate/Result Reviewer:</b>	bruce.muschlitz	<b>Subscriber Preferred Variants:</b>	
<b>Approval Date:</b>	10/21/2020	<b>Subscriber Preferred Rates:</b>	
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	DNV Netherlands (A)		

**Description**  
This certificate and its information was migrated from a previous database

### History

#1 - 07/08/2021 05:00 PM - Herbert Falk

- File 20-2752\_DNVGL\_AccuEnergy\_AcuvimIIW-AXM-WEB2\_ServerEd2\_Certificate.pdf added

### Files

20-2752\_DNVGL\_AccuEnergy\_AcuvimIIW-AXM-WEB2\_ServerEd2\_Certificate.pdf 07/08/2021 Herbert Falk