

IEC 61850 Certificate - IEC 61850 Certificate #2957

MiCOM P40 Agile P94VR Feeder Management [GE Renewable Energy]

07/08/2021 05:00 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	50745.694V.801
61850 Edition:	Edition 2	Certificate Hash:	DFCB1BBB2C0A31BDB9FF95685F72E 621DF4BF6688D5B3A4EC89B57D2A5A F62A2
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	GE Renewable Energy	Vendor Artifact Hash:	
Address:	St. Leonards Building Harry Kerr Drive Stafford ST16 1WT United Kingdom	Umbrella Organization:	
Product:	MiCOM P40 Agile P94VR Feeder Management	Optional Reservation Test:	No
HW Version:	A	Serial Number:	
SW Version:	70B	Publisher Legacy Variants:	
Key Words:	IOC, Protection, Relay, TOC	Publisher Preferred Rates:	
Test Procedure Version:	2.0_rev3	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Preferred Variants:	
Approval Date:	10/23/2020	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	Grid Automation Laboratories (B)		
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 05:00 PM - Herbert Falk

- File 50745.694V.801_GE_P94VR_V70B_Edition2_Certificate.pdf added

#2 - 08/04/2021 09:38 AM - Herbert Falk

- Current Test Lab Name changed from UK Grid Solutions Ltd (B) to Grid Automation Laboratories (B)

Files

50745.694V.801_GE_P94VR_V70B_Edition2_Certificate.pdf	268 KB	07/08/2021	Herbert Falk
---	--------	------------	--------------