

IEC 61850 Certificate - IEC 61850 Certificate #2963

SPiN-IMCU IED [Daewoong Electric Co. Ltd.]

07/08/2021 05:00 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	20TC200893
61850 Edition:	Edition 1	Certificate Hash:	3027B56C47B70905040EBA28EBCD4B 6F895F625DC934D78EF51C45FFA4AD B8A8
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Daewoong Electric Co. Ltd.	Vendor Artifact Hash:	
Address:	Hwanggeumro 127beon-gil10, Yangchon-eup Gimpo-si, Gyeonggi-do, 10048, Republic of Korea	Umbrella Organization:	
Product:	SPiN-IMCU IED	Optional Reservation Test:	No
HW Version:	1.00	Serial Number:	
SW Version:	1.10 MPU version 1.10	Publisher Legacy Variants:	
Key Words:		Publisher Preferred Rates:	
Test Procedure Version:	3.3a	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Preferred Variants:	
Approval Date:	11/19/2020	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	Korea Electrotechnology Research Institute (A)		

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 05:00 PM - Herbert Falk

- File 20TC200893_DAEWOONG_SPiN-IMCU_Server_Ed1_KERI.pdf added

Files

20TC200893_DAEWOONG_SPiN-IMCU_Server_Ed1_KERI.pdf	357 KB	07/08/2021	Herbert Falk
---	--------	------------	--------------