

IEC 61850 Certificate - IEC 61850 Certificate #2965

MCD-HA(506PNA) Line Protection Relay [Mitsubishi Electric Corporation]

07/08/2021 05:00 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	10249379-INC 20-3057
61850 Edition:	Edition 2	Certificate Hash:	0681901B046DC92B85CDCF7443777D 5E73C1A1A62AA4C8EE90D344651DA F46A1
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Mitsubishi Electric Corporation	Vendor Artifact Hash:	
Address:	1-1-2 Wadasaki-Cho, Hyogo-ku 652-8555 Kobe Japan	Umbrella Organization:	
Product:	MCD-HA(506PNA) Line Protection Relay	Optional Reservation Test:	No
HW Version:	506PNA	Serial Number:	
SW Version:	PGLI11 A (61850 version 2.0.1.0)	Publisher Legacy Variants:	
Key Words:	Distance, Protection, Relay	Publisher Preferred Rates:	
Test Procedure Version:	2.0_rev5	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Setting Group (B4), Setting Group Definition (B4+), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Preferred Variants:	
Approval Date:	12/04/2020	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 05:00 PM - Herbert Falk

- File 20-3057 DNVGL_Mitsubishi_MCD-HA_ServerEd2_Certificate.pdf added

Files

20-3057 DNVGL_Mitsubishi_MCD-HA_ServerEd2_Certificate.pdf	116 KB	07/08/2021	Herbert Falk
---	--------	------------	--------------