

IEC 61850 Certificate - IEC 61850 Certificate #2966

MFP-H2SB(652PSA) Overcurrent Protection [Mitsubishi Electric Corporation]

07/08/2021 05:00 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	10249379-INC 20-3053
61850 Edition:	Edition 1	Certificate Hash:	A0F6DFDDE781813B61D8D40BD78BF 98D291F3055C83A89D5C9AF8ED1CC FD1A1A
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Mitsubishi Electric Corporation	Vendor Artifact Hash:	
Address:	1-1-2 Wadasaki-Cho, Hyogo-ku 652-8555 Kobe Japan	Umbrella Organization:	
Product:	MFP-H2SB(652PSA) Overcurrent Protection	Optional Reservation Test:	No
HW Version:	652PSA	Serial Number:	
SW Version:	PGKK48 F (61850 version 2.0.1.0)	Publisher Legacy Variants:	
Key Words:	IOC, Protection, Relay, TOC	Publisher Preferred Rates:	
Test Procedure Version:	3.3	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Preferred Variants:	
Approval Date:	12/04/2020	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 05:00 PM - Herbert Falk

- File 20-3053_DNVGL_Mitsubishi Electric_MFP-H2SB_ServerEd1_Certificate.pdf added

Files

20-3053_DNVGL_Mitsubishi Electric_MFP-H2SB_ServerEd1_Certificate.pdf	15 KB	07/08/2021	Herbert Falk
--	-------	------------	--------------