

IEC 61850 Certificate - IEC 61850 Certificate #2968

PCS-9613S Differential Relay [NR Electric Co., Ltd.]

07/08/2021 05:00 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	D 061589 0154 Rev. 00
61850 Edition:	Edition 2	Certificate Hash:	BC866378535EB625D7AF1FB94DEC8F34D3F7CE7A1670EE56CCBEB1BE2854493E
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	NR Electric Co., Ltd.	Vendor Artifact Hash:	
Address:	69 Suyuan Avenue 211102 Nanjing China	Umbrella Organization:	
Product:	PCS-9613S Differential Relay	Optional Reservation Test:	No
HW Version:	NR6106-3 (S/N: K380184800101)	Serial Number:	
SW Version:	Ed2 2.00	Publisher Legacy Variants:	
Key Words:	Differential, Protection	Publisher Preferred Rates:	
Test Procedure Version:	2.0_rev5	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Service Tracking (B15), Setting Group (B4), Setting Group Definition (B4+), Substitution (B3), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Preferred Variants:	
Approval Date:	12/08/2020	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	TUV SUD China Ltd (A)		
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 05:00 PM - Herbert Falk

- File 20-D 061589 0154 Rev. 00-NR Electric_PCS-9613S_IEC61850Ed2-Server-Cert added

#2 - 07/11/2021 11:02 AM - Herbert Falk

- File 20-D 061589 0154 Rev. 00-NR Electric_PCS-9613S_IEC61850Ed2-Server-Certificate.pdf added

- Address updated

#3 - 07/11/2021 11:02 AM - Herbert Falk

- File deleted (20-D 061589 0154 Rev. 00-NR Electric_PCS-9613S_IEC61850Ed2-Server-Cert)

Files

20-D 061589 0154 Rev. 00-NR Electric_PCS-9613S_IEC61850Ed2-SerialCertificate.pdf 1.05 MB 07/11/2021

Herbert Falk