IEC 61850 Certificate - IEC 61850 Certificate #2971

GRE200 Multi Functional Protection [TOSHIBA Corporation]

07/08/2021 05:00 PM - Herbert Falk

Status:	Approved		
Priority:	Normal		
61850 Edition:	Edition 2	**Certificate Name:**	10261725-INC 20-3154
61850 Tested Aspects:	Server	**Certificate Hash:**	6B1E3F8141EC6D06352F2D6110BF2C5BF647F42F066FA67F531E990606BC951C
Company:	TOSHIBA Corporation	**Vendor Artifact File Name:**	
Address:	Power Systems Protection and Control Dept. Fuchu Complex 1, TOSHIBA-Cho Fuchu-shi, Tokyo, 183-8511 Japan	**Vendor Artifact Hash:**	
Product:	GRE200 Multi Functional Protection	**Umbrella Organization:**	
HW Version:	GRE200-11-1M1-00-LL-51-AA0	**Optional Reservation Test:**	No
SW Version:	GS2REIM13003 (61850=G2M85002A)	**Serial Number:**	
Key Words:	IOC, Protection, Relay, TOC	**Publisher Legacy Variants:**	
Test Procedure Version:	2.0_rev5	**Publisher Preferred Rates:**	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Service Tracking (B15), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	**Publisher Preferred Variants:**	
Certificate/Result Reviewer:	bruce.muschlitz	**Subscriber Legacy Variants:**	
Approval Date:	12/16/2020	**Subscriber Preferred Variants:**	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	**Subscriber Preferred Rates:**	
Current Test Lab Name:	DNV Netherlands (A)	**Product Variants:**	
Test Document:			

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 05:00 PM - Herbert Falk

- File 20-3154_DNVGL_Toshiba_GRE200_ServerEd2_Certificate.pdf added

Files

20-3154_DNVGL_Toshiba_GRE200_ServerEd2_Certificate.pdf	116 KB	07/08/2021	Herbert Falk