

IEC 61850 Certificate - IEC 61850 Certificate #2974

AQ-300: AQ-L359 Line protection IED [Arcteq Relays Ltd.]

07/08/2021 05:00 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	10261711-INC 20-3093
61850 Edition:	Edition 2	Certificate Hash:	1817CA665B618C4EA582A882B0BB38 8724DA5925BDE00DD848D4F37B9BB7 A7C7
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Arcteq Relays Ltd.	Vendor Artifact Hash:	
Address:	Kvartsikatu 2A1 65300 Vaasa Finland	Umbrella Organization:	
Product:	AQ-300: AQ-L359 Line protection IED	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	2.10 revision 1.3000	Publisher Legacy Variants:	
Key Words:	Distance, Protection, Relay	Publisher Preferred Rates:	
Test Procedure Version:	2.0.3	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Service Tracking (B15), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Preferred Variants:	
Approval Date:	12/19/2020	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 05:00 PM - Herbert Falk

- File 20-3093_DNVGL_Arcteq_AQ300_ServerEd2_Certificate.pdf added

Files

20-3093_DNVGL_Arcteq_AQ300_ServerEd2_Certificate.pdf	116 KB	07/08/2021	Herbert Falk
--	--------	------------	--------------