

IEC 61850 Certificate - IEC 61850 Certificate #2975

DW-SPiN IEC 61850 Client Multi-HMI [Daewoong Electric Co. Ltd.]

07/08/2021 05:00 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	20TC200977
61850 Edition:	Edition 1	Certificate Hash:	31B51BF1AE53D09D35AB22DA6DD68 C1C748878F84CDA79502686A887E49 83148
61850 Tested Aspects:	Client	Vendor Artifact File Name:	
Company:	Daewoong Electric Co. Ltd.	Vendor Artifact Hash:	
Address:	Hwanggeumro 127beon-gil10, Yangchon-eup Gimpo-si, Gyeonggi-do, 10048, Republic of Korea	Umbrella Organization:	
Product:	DW-SPiN IEC 61850 Client Multi-HMI	Optional Reservation Test:	No
HW Version:	Windows Server (2019)	Serial Number:	
SW Version:	1.0.0	Publisher Legacy Variants:	
Key Words:	HMI	Publisher Preferred Rates:	
Test Procedure Version:	1.1	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), SBO Control (12b), Setting Group (B4), Setting Group Definition (B4+), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Preferred Variants:	
Approval Date:	12/22/2020		
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	Korea Electrotechnology Research Institute (A)		
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/10/2021 06:20 PM - Herbert Falk

- File 20TC200977_Daewoong_DW-SPiN_IEC61850M-HMI_Client_Ed1_KERI.pdf added

- Address updated

Files

20TC200977_Daewoong_DW-SPiN_IEC61850M-HMI_Client_Ed1_KERI.pdf	334 KB	07/10/2021	Herbert Falk
---	--------	------------	--------------