IEC 61850 Certificate - IEC 61850 Certificate #2977

Multilin G500 Advanced Substation Gatewa [GE Multilin]

07/08/2021 05:01 PM - Herbert Falk

Status: Approved

Priority: Normal

61850 Edition: Edition 2

61850 Tested Aspects:

Company: GE Multilin

Address: 650 Markland St.

Markham, ON L6C 0M1

Canada

Client

Product: Multilin G500 Advanced Substation

Gatewa

G500-B **HW Version:**

SW Version: G500 v2.10

Key Words: Gateway Test Procedure

Version:

1.1.2(rev2

IEC 61850 Blocks

Basic Exchange (B1), Buffered Certified: Reporting (B6), Data Set Definition

> (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), SBO Control (12b), Time Synchronization (B13), Unbuffered Reporting (B5)

Certificate/Result

Reviewer:

bruce.muschlitz

Approval Date: 01/08/2021

61850-6, 61850-7-1, 61850-7-2,

61850-7-3, 61850-7-4, 61850-8-1

Current Test Lab

Standards Tested:

Name:

Grid Automation Laboratories (B)

Name:

Test Document:

Certificate Name:

Certificate Hash:

50745.6G500.801

5B99

7AE784BF53D1E50C0975C536C3AED5 3BD9FD32B00B30793ED055C77D19FD

Vendor Artifact Hash:

Vendor Artifact File

Umbrella Organization:

Optional Reservation Yes

Test:

Publisher Legacy

Serial Number:

Variants:

Publisher Preferred

Rates:

Publisher Preferred

Variants:

Subscriber Legacy

Variants:

Subscriber Preferred

Variants:

Subscriber Preferred

Rates:

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 05:01 PM - Herbert Falk

- File 50745.6G500.801_GE_Multilin_G500_Gateway_V2.10_Edition2_Client_Certifi added

#2 - 07/11/2021 10:16 AM - Herbert Falk

- Address updated
- Optional Reservation Test changed from No to Yes

#3 - 07/11/2021 11:01 AM - Herbert Falk

- File 50745.6G500.801_GE Multilin G500 Gateway V2.10 Edition2 Client Certificate.pdf added

04/25/2024 1/2

#4 - 07/11/2021 11:01 AM - Herbert Falk

- File deleted (50745.6G500.801_GE_Multilin_G500_Gateway_V2.10_Edition2_Client_Certifi)

#5 - 08/04/2021 09:38 AM - Herbert Falk

- Current Test Lab Name changed from UK Grid Solutions Ltd (B) to Grid Automation Laboratories (B)

Files

 $50745.6G500.801_GE_Multilin_G500_Gateway_V2.10_Edition2_Clien \textbf{2.5Se} \textbf{MB} cate.pdf \ 07/11/2021$

Herbert Falk

04/25/2024 2/2