

IEC 61850 Certificate - IEC 61850 Certificate #2980

TPA-01 (???-01) Protection, Automation, [Prosoft-Systems Ltd.]

07/08/2021 05:01 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	10270573-INC 20-3212
61850 Edition:	Edition 2	Certificate Hash:	051C2A5DB9807647BDBD211E2C532D D7B9FA498D95F8C3CE277852B5E0AE E64A
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Prosoft-Systems Ltd.	Vendor Artifact Hash:	
Address:	194a Volgogradskaya St. 620102 Ekaterinburg Russian Federation	Umbrella Organization:	
Product:	TPA-01 (???-01) Protection, Automation,	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	3.0	Publisher Legacy Variants:	
Key Words:	Protection	Publisher Preferred Rates:	
Test Procedure Version:	2.0_rev5	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Setting Group (B4), Setting Group Definition (B4+), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Preferred Variants:	
Approval Date:	02/11/2021		
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 05:01 PM - Herbert Falk

- File 20-3212_DNVGL_ProSoft_TPA-01_ServerEd2_Certificate.pdf added

Files

20-3212_DNVGL_ProSoft_TPA-01_ServerEd2_Certificate.pdf	115 KB	07/08/2021	Herbert Falk
--	--------	------------	--------------