

IEC 61850 Certificate - IEC 61850 Certificate #2981

SMART-KP2 (?????-???) Power facility lev [RTSoft, AO]

07/08/2021 05:01 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	10270573 -INC 20-3218
61850 Edition:	Edition 2	Certificate Hash:	978AD9934EE4DE89E5008E4344E1CD A582B34F385662EFBBECF46CBB3D2 ECEBF
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	RTSoft, AO	Vendor Artifact Hash:	
Address:	Severny Proezd, 1, Chernogolovka Moscow region, 142432 Russian Federation	Umbrella Organization:	
Product:	SMART-KP2 (?????-???) Power facility lev	Optional Reservation Test:	No
HW Version:	????421457.618	Serial Number:	
SW Version:	1.0.1	Publisher Legacy Variants:	
Key Words:		Publisher Preferred Rates:	
Test Procedure Version:	2.0_rev5	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Preferred Variants:	
Approval Date:	02/11/2021	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 05:01 PM - Herbert Falk

- File 20-3218_DNVGL_RTSoft_SMART-KP2_ServerEd2_Certificate.pdf added

Files

20-3218_DNVGL_RTSoft_SMART-KP2_ServerEd2_Certificate.pdf	115 KB	07/08/2021	Herbert Falk
--	--------	------------	--------------