

IEC 61850 Certificate - IEC 61850 Certificate #2984

SWIED-CU100 IEC61850 Communication Unit [SEWON Systech Ltd.]

07/08/2021 05:01 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	20-029521-01-2
61850 Edition:	Edition 1	Certificate Hash:	FFA4B3409844FFA69E32CADDDFE2C C54342A92E203CE45CD5F65B2C036E AE74C
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	SEWON Systech Ltd.	Vendor Artifact Hash:	
Address:	76, LS-ro, Dongan-gu, Anyang-si, Gyeonggi-do, Republic of Korea 14117	Umbrella Organization:	
Product:	SWIED-CU100 IEC61850 Communication Unit	Optional Reservation Test:	No
HW Version:	Windows 10	Serial Number:	
SW Version:	1.0	Publisher Legacy Variants:	
Key Words:	Comm	Publisher Preferred Rates:	
Test Procedure Version:	3.3	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Data Sets (B2), Enhanced SBO Control (12d), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Preferred Variants:	
Approval Date:	02/18/2021	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	Korea Testing Laboratory (A)		
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 05:01 PM - Herbert Falk

- File 20-029521-01-2_SEWON_SWIED-CU100_Server_Ed1_Certification_KTL.pdf added

Files

20-029521-01-2_SEWON_SWIED-CU100_Server_Ed1_Certification_KTL.pdf

07/08/2021

Herbert Falk