

IEC 61850 Certificate - IEC 61850 Certificate #2986

AQ-250: AQ-F255 Feeder protection IED [Arcteq Relays Ltd.]

07/08/2021 05:01 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	10246988-INC 21-2640
61850 Edition:	Edition 2	Certificate Hash:	0CED3D0C109C416386A7C9EAEFB49 83BB32B2F474D2DB6572C8838BCBD5 A6965
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Arcteq Relays Ltd.	Vendor Artifact Hash:	
Address:	Kvartsikatu 2A1 65300 Vaasa Finland	Umbrella Organization:	
Product:	AQ-250: AQ-F255 Feeder protection IED	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	v2.5.7.1	Publisher Legacy Variants:	
Key Words:	IOC, Protection, Relay, TOC	Publisher Preferred Rates:	
Test Procedure Version:	2.0_rev4	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Preferred Variants:	
Approval Date:	03/11/2021	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 05:01 PM - Herbert Falk

- File 21-2640_DNVGL_ARCTEQ_F255_ServerEd2_Certificate.pdf added

Files

21-2640_DNVGL_ARCTEQ_F255_ServerEd2_Certificate.pdf	116 KB	07/08/2021	Herbert Falk
-----------------------------------------------------	--------	------------	--------------