

IEC 61850 Certificate - IEC 61850 Certificate #2987

ESM-HV400-24-A2E4-02S with ENMV-1 [Engineering Center Energoservice]

07/08/2021 05:01 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	10280728-INC 21-2602
61850 Edition:	Edition 2	Certificate Hash:	53669005DD7C9A07840B2A153B8AD1 9205E1E5C8F92C38055F4D08403B533 A39
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Engineering Center Energoservice	Vendor Artifact Hash:	
Address:	44, Aviamotornaya street, Bld 1 Office 1A, Room 1 Moscow, 111024 Russian Federation	Umbrella Organization:	
Product:	ESM-HV400-24-A2E4-02S with ENMV-1	Optional Reservation Test:	No
HW Version:	3.1	Serial Number:	
SW Version:	1.0.0.0. rev.910	Publisher Legacy Variants:	
Key Words:	Measurement, Meter	Publisher Preferred Rates:	
Test Procedure Version:	2.0.4	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Preferred Variants:	
Approval Date:	03/23/2021	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 05:01 PM - Herbert Falk

- File 21-2602_DNV_Energoservice_ESM_ServerEd2_Certificate.pdf added

Files

21-2602_DNV_Energoservice_ESM_ServerEd2_Certificate.pdf	114 KB	07/08/2021	Herbert Falk
---	--------	------------	--------------