

IEC 61850 Certificate - IEC 61850 Certificate #2988

APM5000 Server Partial Discharge Monitor [Advanced Power Management Co.]

07/08/2021 05:01 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	21TC200185
61850 Edition:	Edition 1	Certificate Hash:	AB8F1ED1942B0C4846E6A79C5D5945 FEFD6731D0B6029CE7DCBD53D2950 C7A8F
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Advanced Power Management Co.	Vendor Artifact Hash:	
Address:	2nd Industrial city, Kharj road, Riyadh, Kingdom of Saudi Arabia	Umbrella Organization:	
Product:	APM5000 Server Partial Discharge Monitor	Optional Reservation Test:	No
HW Version:	Advantech UNO-4683, Win2012R2Std	Serial Number:	
SW Version:	1.0	Publisher Legacy Variants:	
Key Words:	Measurement	Publisher Preferred Rates:	
Test Procedure Version:	3.3a	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Data Set Definition (B2+), Data Sets (B2), Enhanced SBO Control (12d), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Preferred Variants:	
Approval Date:	03/24/2021	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	Korea Electrotechnology Research Institute (A)		
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 05:01 PM - Herbert Falk

- File 21TC200185_APM_APM5000_Server_Ed1_KERI.pdf added

Files

21TC200185_APM_APM5000_Server_Ed1_KERI.pdf

2.11 MB

07/08/2021

Herbert Falk