

IEC 61850 Certificate - IEC 61850 Certificate #2989

MVR-F255 Feeder protection IED [DEIF A/S]

07/08/2021 05:01 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	10246988-INC 21-2659
61850 Edition:	Edition 2	Certificate Hash:	A42A2C075C478717FDA0D5E25F33C8 A81B1BCE8BC5195B04BA7E688A1C3 F029B
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	DEIF A/S	Vendor Artifact Hash:	
Address:	Frisenborgvej 33 7800 Skive Denmark	Umbrella Organization:	
Product:	MVR-F255 Feeder protection IED	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	2.5.7.1	Publisher Legacy Variants:	
Key Words:	IOC, Protection, Relay, TOC	Publisher Preferred Rates:	
Test Procedure Version:	2.0_rev4	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Preferred Variants:	
Approval Date:	03/26/2021	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 05:01 PM - Herbert Falk

- File 21-2659_DNVGL_DEIF_F255_ServerEd2_Certificate.pdf added

Files

21-2659_DNVGL_DEIF_F255_ServerEd2_Certificate.pdf	116 KB	07/08/2021	Herbert Falk
---	--------	------------	--------------