# IEC 61850 Certificate - IEC 61850 Certificate #2992

## SMD-K020 Subsation Automation Informatio [Sanion Co., Ltd.]

07/08/2021 05:01 PM - Herbert Falk

| | | | |
|---|---|---|---|
| **Status:** | Approved | | |
| **Priority:** | Normal | | |
| **61850 Edition:** | Edition 1 | **Certificate Name:** | 20-074480-03-5 |
| **61850 Tested Aspects:** | Server | **Certificate Hash:** | 10FCCCD1094AF4CE0ED5EE29DBD2E2C9618E6752DD17972FBAFF3936AA83126B |
| **Company:** | Sanion Co., Ltd. | **Vendor Artifact File Name:** | |
| **Address:** | 13, Geomdan-ro, 114beon-gil, Seo-gu, Incheon, Republic of Korea, 22663 | **Vendor Artifact Hash:** | |
| **Product:** | SMD-K020 Subsation Automation Informatio | **Umbrella Organization:** | |
| **HW Version:** | SMD-K020 Windows Server 2016 | **Optional Reservation Test:** | No |
| **SW Version:** | 1.0 | **Serial Number:** | |
| **Key Words:** | Comm, RTU | **Publisher Legacy Variants:** | |
| **Test Procedure Version:** | 3.3 | **Publisher Preferred Rates:** | |
| **IEC 61850 Blocks Certified:** | Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), Time Synchronization (B13), Unbuffered Reporting (B5) | **Publisher Preferred Variants:** | |
| **Certificate/Result Reviewer:** | bruce.muschlitz | **Subscriber Legacy Variants:** | |
| **Approval Date:** | 03/26/2021 | **Subscriber Preferred Variants:** | |
| **Standards Tested:** | 61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1 | **Subscriber Preferred Rates:** | |
| **Current Test Lab Name:** | Korea Testing Laboratory (A) | **Product Variants:** | |
| **Test Document:** | | | |

**Description**

This certificate and its information was migrated from a previous database

### History

**#1 - 07/08/2021 05:01 PM - Herbert Falk**

*- File 20-074480-03-5_SANION_SMD-K020_Server_Ed1_Certification_KTL.pdf added*

### Files

| | | | |
|---|---|---|---|
| 20-074480-03-5_SANION_SMD-K020_Server_Ed1_Certification_KTL.pdf | 624 KB | 07/08/2021 | Herbert Falk |