

IEC 61850 Certificate - IEC 61850 Certificate #2992

SMD-K020 Substation Automation Informatio [Sanion Co., Ltd.]

07/08/2021 05:01 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	20-074480-03-5
61850 Edition:	Edition 1	Certificate Hash:	10FCCCD1094AF4CE0ED5EE29DBD2 E2C9618E6752DD17972FB AFF3936AA 83126B
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	Sanion Co., Ltd.	Vendor Artifact Hash:	
Address:	13, Geomdan-ro, 114beon-gil, Seo-gu, Incheon, Republic of Korea, 22663	Umbrella Organization:	
Product:	SMD-K020 Substation Automation Informatio	Optional Reservation Test:	No
HW Version:	SMD-K020 Windows Server 2016	Serial Number:	
SW Version:	1.0	Publisher Legacy Variants:	
Key Words:	Comm, RTU	Publisher Preferred Rates:	
Test Procedure Version:	3.3	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Preferred Variants:	
Approval Date:	03/26/2021	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	Korea Testing Laboratory (A)		

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 05:01 PM - Herbert Falk

- File 20-074480-03-5_SANION_SMD-K020_Server_Ed1_Certification_KTL.pdf added

Files

20-074480-03-5_SANION_SMD-K020_Server_Ed1_Certification_KTL.pdf	624 KB	07/08/2021	Herbert Falk
---	--------	------------	--------------