

IEC 61850 Certificate - IEC 61850 Certificate #2995

IED K-IEC BC100 [Kyongbo Electric Co., Ltd.]

07/08/2021 05:01 PM - Herbert Falk

Status:	Approved	
Priority:	Normal	
61850 Edition:	Edition 1	Certificate Name: 21TC200301
61850 Tested Aspects:	Server	Certificate Hash: 95FF927131A20CEFB6FC6559A7CE2533046E03D74B2411A867CCB48B5A9EA076
Company:	Kyongbo Electric Co., Ltd.	Vendor Artifact File Name:
Address:	5, Seongsuil-ro, 12ga-gil, Seongdong-gu, Seoul, 04792, Republic of Korea	Vendor Artifact Hash:
Product:	IED K-IEC BC100	Umbrella Organization:
HW Version:		Optional Reservation Test: No
SW Version:	MCU: 1.00; DSP: 1.00; Comm: 1.00	Serial Number:
Key Words:		Publisher Legacy Variants:
Test Procedure Version:	3.3a	Publisher Preferred Rates:
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Substitution (B3), Time Synchronization (B13), Unbuffered Reporting (B5)	Publisher Preferred Variants:
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Legacy Variants:
Approval Date:	04/28/2021	Subscriber Preferred Variants:
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	Subscriber Preferred Rates:
Current Test Lab Name:	Korea Electrotechnology Research Institute (A)	Product Variants:
Test Document:		Time Activated Control:
Description This certificate and its information was migrated from a previous database		

History

#1 - 07/08/2021 05:01 PM - Herbert Falk

- File 21TC200301_Kyongbo_K-IED_BC100_Server_Ed1_KERI.pdf added

Files

21TC200301_Kyongbo_K-IED_BC100_Server_Ed1_KERI.pdf	378 KB	07/08/2021	Herbert Falk
--	--------	------------	--------------