

IEC 61850 Certificate - IEC 61850 Certificate #2998

IED PAC-NX100 [PNC Technologies Co., Ltd.]

07/08/2021 05:01 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	21TC200309
61850 Edition:	Edition 1	Certificate Hash:	EF9990417DCF14C0CD92829AD124D DCB1F535F910D35A6661EE2318B925 E8BCC
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	PNC Technologies Co., Ltd.	Vendor Artifact Hash:	
Address:	62, Jeonpa-ro 104beon-gil, Dongan-gu, Anyang-si. Gyeonggi-do, 14042 Republic of Korea	Umbrella Organization:	
Product:	IED PAC-NX100	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	MPU: 1.00; DSP: F11.2.03	Publisher Legacy Variants:	
Key Words:		Publisher Preferred Rates:	
Test Procedure Version:	3.3a	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Substitution (B3), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Preferred Variants:	
Approval Date:	04/29/2021	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	Korea Electrotechnology Research Institute (A)		

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 05:01 PM - Herbert Falk

- File 21TC200309_PNC_TECH_PAC-NX100_Server_Ed1_KERI.pdf added

Files

21TC200309_PNC_TECH_PAC-NX100_Server_Ed1_KERI.pdf	365 KB	07/08/2021	Herbert Falk
---	--------	------------	--------------