

IEC 61850 Certificate - IEC 61850 Certificate #3000

SAS-PYLON-V2 Substation AutomationSystem [PNC Technologies Co., Ltd.]

07/08/2021 05:01 PM - Herbert Falk

<p>Status: Approved</p> <p>Priority: Normal</p> <p>61850 Edition: Edition 1</p> <p>61850 Tested Aspects: Server</p> <p>Company: PNC Technologies Co., Ltd.</p> <p>Address: 62, Jeonpa-ro 104beon-gil, Dongan-gu, Anyang-si. Gyeonggi-do, 14042 Republic of Korea</p> <p>Product: SAS-PYLON-V2 Substation AutomationSystem</p> <p>HW Version: ECU-4784 Windows Server 2016</p> <p>SW Version: 2.0</p> <p>Key Words: RTU</p> <p>Test Procedure Version: 3.3</p> <p>IEC 61850 Blocks Certified: Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), SBO Control (12b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)</p> <p>Certificate/Result Reviewer: bruce.muschlitz</p> <p>Approval Date: 04/30/2021</p> <p>Standards Tested: 61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1</p> <p>Current Test Lab Name: Korea Testing Laboratory (A)</p>	<p>Test Document:</p> <p>Certificate Name: 21-003589-01-2</p> <p>Certificate Hash: 0A733D864C3839AB6CFCE06AD240BFA6437883EAD0AC74463D64D44A8860B2B4</p> <p>Vendor Artifact File Name:</p> <p>Vendor Artifact Hash:</p> <p>Umbrella Organization:</p> <p>Optional Reservation Test: No</p> <p>Serial Number:</p> <p>Publisher Legacy Variants:</p> <p>Publisher Preferred Rates:</p> <p>Publisher Preferred Variants:</p> <p>Subscriber Legacy Variants:</p> <p>Subscriber Preferred Variants:</p> <p>Subscriber Preferred Rates:</p>
<p>Description</p> <p>This certificate and its information was migrated from a previous database</p>	

History

#1 - 07/08/2021 05:01 PM - Herbert Falk

- File 21-003589-01-2_PNCTech_SAS-PYLON-V2_Server_Ed1_Certification_KTL.pdf added

Files

21-003589-01-2_PNCTech_SAS-PYLON-V2_Server_Ed1_Certification165 KB	07/08/2021	Herbert Falk
--	------------	--------------