

IEC 61850 Certificate - IEC 61850 Certificate #3002

NSR-371 BUSBAR PROTECTION [NARI Technology Co., Ltd.]

07/08/2021 05:01 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	GCP20211624
61850 Edition:	Edition 2	Certificate Hash:	EBD8BF2D66A5193C5B7C5C4566B2A 87C2EC113E1B844678DB938DDB3C0 C7365E
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	NARI Technology Co., Ltd.	Vendor Artifact Hash:	
Address:	Industrial Building 3rd Floor, No.19 Chengxin Avenue, 211106, Nanjing, China	Umbrella Organization:	
Product:	NSR-371 BUSBAR PROTECTION	Optional Reservation Test:	No
HW Version:	1.10	Serial Number:	
SW Version:	1.31	Publisher Legacy Variants:	
Key Words:	Differential, Protection, Relay	Publisher Preferred Rates:	
Test Procedure Version:	2.0.4	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Setting Group (B4), Setting Group Definition (B4+), Substitution (B3), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Preferred Variants:	
Approval Date:	05/11/2021	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	State Grid Electric Power Research Institute (A)		

Description

This certificate and its information was migrated from a previous database

History

#1 - 07/08/2021 05:02 PM - Herbert Falk

- File GCP20211624_ServerEd2_Certificate_PAL.pdf added

Files

GCP20211624_ServerEd2_Certificate_PAL.pdf	2.9 MB	07/08/2021	Herbert Falk
---	--------	------------	--------------