

# IEC 61850 Certificate - IEC 61850 Certificate #3003

## NSR-378 TRANSFORMER PROTECTION [NARI Technology Co., Ltd.]

07/08/2021 05:02 PM - Herbert Falk

<b>Status:</b>	Approved	<b>Test Document:</b>	
<b>Priority:</b>	Normal	<b>Certificate Name:</b>	GCP20211625
<b>61850 Edition:</b>	Edition 2	<b>Certificate Hash:</b>	0BCA63EC136884BE65FF231FE886D0 B44F881484960994563D57C45989640 E6D
<b>61850 Tested Aspects:</b>	Server	<b>Vendor Artifact File Name:</b>	
<b>Company:</b>	NARI Technology Co., Ltd.	<b>Vendor Artifact Hash:</b>	
<b>Address:</b>	Industrial Building 3rd Floor, No.19 Chengxin Avenue, 211106, Nanjing, China	<b>Umbrella Organization:</b>	
<b>Product:</b>	NSR-378 TRANSFORMER PROTECTION	<b>Optional Reservation Test:</b>	No
<b>HW Version:</b>	1.10	<b>Serial Number:</b>	
<b>SW Version:</b>	2.00	<b>Publisher Legacy Variants:</b>	
<b>Key Words:</b>	Differential, Protection, Relay	<b>Publisher Preferred Rates:</b>	
<b>Test Procedure Version:</b>	2.0.4	<b>Publisher Preferred Variants:</b>	
<b>IEC 61850 Blocks Certified:</b>	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), Setting Group (B4), Setting Group Definition (B4+), Substitution (B3), Time Synchronization (B13), Unbuffered Reporting (B5)	<b>Subscriber Legacy Variants:</b>	
<b>Certificate/Result Reviewer:</b>	bruce.muschlitz	<b>Subscriber Preferred Variants:</b>	
<b>Approval Date:</b>	05/11/2021	<b>Subscriber Preferred Rates:</b>	
<b>Standards Tested:</b>	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
<b>Current Test Lab Name:</b>	State Grid Electric Power Research Institute (A)		
<b>Description</b>			
This certificate and its information was migrated from a previous database			

### History

#1 - 07/08/2021 05:02 PM - Herbert Falk

- File GCP20211625\_ServerEd2\_Certificate\_PAL.pdf added

### Files

GCP20211625_ServerEd2_Certificate_PAL.pdf	2.91 MB	07/08/2021	Herbert Falk
---	---------	------------	--------------