

IEC 61850 Certificate - IEC 61850 Certificate #3004

MiCOM P40 Agile P14NB Feeder Management [GE Renewable Energy]

07/08/2021 05:02 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	50745.614N.804
61850 Edition:	Edition 1	Certificate Hash:	AF7B8CAF89D1FF2AB90EA582DD865 03CE0BA4A744550DE37F4266C3034A 15CB8
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	GE Renewable Energy	Vendor Artifact Hash:	
Address:	St. Leonards Building Harry Kerr Drive, Stafford UK, ST16 1WT	Umbrella Organization:	
Product:	MiCOM P40 Agile P14NB Feeder Management	Optional Reservation Test:	No
HW Version:	A	Serial Number:	
SW Version:	62F	Publisher Legacy Variants:	
Key Words:	IOC, Protection, Relay, TOC	Publisher Preferred Rates:	
Test Procedure Version:	3.3	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Preferred Variants:	
Approval Date:	05/20/2021	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	Grid Automation Laboratories (B)		
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 05:02 PM - Herbert Falk

- File 50745.614N.804_GE_P14NB_V62_Edition1_Certificate.pdf added

#2 - 08/04/2021 09:38 AM - Herbert Falk

- Current Test Lab Name changed from UK Grid Solutions Ltd (B) to Grid Automation Laboratories (B)

Files

50745.614N.804_GE_P14NB_V62_Edition1_Certificate.pdf	254 KB	07/08/2021	Herbert Falk
--	--------	------------	--------------