

IEC 61850 Certificate - IEC 61850 Certificate #3010

iEMS-10-IEC61850-Gateway [ControlNet International Inc.]

07/08/2021 05:02 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	20-11-CAV-031
61850 Edition:	Edition 2	Certificate Hash:	DD9DD79293C6B418791DD80A2FC2F 203886049C61F47E08D7912D0416524 E31B
61850 Tested Aspects:	Client	Vendor Artifact File Name:	
Company:	ControlNet International Inc.	Vendor Artifact Hash:	
Address:	3rd Floor, No.33, 35, Lane 21, Sec.6, Minchuan E. Rd., Neihu District, Taipei 11494, Taiwan	Umbrella Organization:	
Product:	iEMS-10-IEC61850-Gateway	Optional Reservation Test:	No
HW Version:		Serial Number:	
SW Version:	1.0	Publisher Legacy Variants:	
Key Words:	Gateway	Publisher Preferred Rates:	
Test Procedure Version:	1.1	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), SBO Control (12b), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Preferred Variants:	
Approval Date:	06/22/2021	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	Taiwan Testing and Certification Center (A)		
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 05:02 PM - Herbert Falk

- File iEMS-10-IEC61850-Gateway clientEd2_Certificate.pdf added

Files

iEMS-10-IEC61850-Gateway clientEd2_Certificate.pdf	366 KB	07/08/2021	Herbert Falk
--	--------	------------	--------------