

IEC 61850 Certificate - IEC 61850 Certificate #3011

SAS-PYLON-V2 Substation Automation System [PNC Technologies Co., Ltd.]

07/08/2021 05:02 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	21-003589-02-1
61850 Edition:	Edition 2	Certificate Hash:	D7EDE4339957DCC7E7E2DF597DC2A F08CD2F0473DA2D9D79D2C2ADAD57 9C1C24
61850 Tested Aspects:	Client	Vendor Artifact File Name:	
Company:	PNC Technologies Co., Ltd.	Vendor Artifact Hash:	
Address:	62, Jeonpa-ro 104beon-gil, Dongan-gu, Anyang-si. Gyeonggi-do, 14042 Republic of Korea	Umbrella Organization:	
Product:	SAS-PYLON-V2 Substation Automation System	Optional Reservation Test:	Yes
HW Version:	ECU-4784 Windows Server 2016	Serial Number:	
SW Version:	2.0	Publisher Legacy Variants:	
Key Words:		Publisher Preferred Rates:	
Test Procedure Version:	1.2	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Set Definition (B2+), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), SBO Control (12b), Service Tracking (B15), Setting Group (B4), Setting Group Definition (B4+), Substitution (B3), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Preferred Variants:	
Approval Date:	06/25/2021	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	Korea Testing Laboratory (A)		
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 05:02 PM - Herbert Falk

- File 21-003589-02-1_PNCTech_SAS-PYLON-V2_Client_Ed2_TP_1p2_Certificate_KTL. added

#2 - 07/11/2021 10:17 AM - Herbert Falk

- Address updated

- Optional Reservation Test changed from No to Yes

#3 - 07/11/2021 10:56 AM - Herbert Falk

- File 21-003589-02-1_PNCTech_SAS-PYLON-V2_Client_Ed2_TP_1p2_Certificate_KTL.PDF added

#4 - 07/11/2021 10:56 AM - Herbert Falk

- File deleted (21-003589-02-1_PNCTech_SAS-PYLON-V2_Client_Ed2_TP_1p2_Certificate_KTL.)

Files

21-003589-02-1_PNCTech_SAS-PYLON-V2_Client_Ed2_TP_1p2_Certificate_KTL.PDF 165 KB 07/11/2021

Herbert Falk