

IEC 61850 Certificate - IEC 61850 Certificate #3012

MiCOM AGILE P741 BUSBAR DIFFERENTIAL PRO [M/s. GE T&D India Ltd.]

07/08/2021 05:02 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	CPRIBLRMUADSASL21TC0001
61850 Edition:	Edition 2	Certificate Hash:	FE897D51E31EA4A116F0F6838A2E2E EDB05DC72E897EF82FCC80DEDB912 EBA73
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	M/s. GE T&D India Ltd.	Vendor Artifact Hash:	
Address:	19/1, G.S.T. ROAD, PALLAVARAM, CHENNAI - 600043 INDIA	Umbrella Organization:	
Product:	MiCOM AGILE P741 BUSBAR DIFFERENTIAL PRO	Optional Reservation Test:	No
HW Version:	P741-K Hardware	Serial Number:	
SW Version:	70	Publisher Legacy Variants:	
Key Words:	Differential, Protection, Relay	Publisher Preferred Rates:	
Test Procedure Version:	2.0_rev4	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), GOOSE Publish (9a), GOOSE Subscribe (9b), SBO Control (12b), Setting Group (B4), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	bruce.muschlitz	Subscriber Preferred Variants:	
Approval Date:	07/01/2021	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	Central Power Research Institute India (A)		
Description			
This certificate and its information was migrated from a previous database			

History

#1 - 07/08/2021 05:02 PM - Herbert Falk

- File GE T and D India Ltd_P741_CPRIBLRMUADSASL21TC0001.pdf added

Files

GE T and D India Ltd_P741_CPRIBLRMUADSASL21TC0001.pdf	916 KB	07/08/2021	Herbert Falk
---	--------	------------	--------------