

IEC 61850 Certificate - IEC 61850 Certificate #3014

EcoSUI-PACiS local HMI [Schneider Electric]

07/08/2021 05:31 PM - Herbert Falk

Status:	Approved	
Priority:	Normal	
61850 Edition:	Edition 2	Certificate Name: 10021185-OPE/INC 16-2082
61850 Tested Aspects:	Client	Certificate Hash: 057C1A387AD8C5022030CF7EED81072A88BC8F2CF49D7496D48600E91BF56911
Company:	Schneider Electric	Vendor Artifact File Name:
Address:	Avenue de Figuières 34975 Lattes France	Vendor Artifact Hash:
Product:	EcoSUI-PACiS local HMI	Umbrella Organization: Schneider Electric
HW Version:	Dell Precision T5500 Win7-64 SP1	Optional Reservation Test: No
SW Version:	2.1.16272.50	Serial Number:
Key Words:	Comm	Publisher Legacy Variants:
Test Procedure Version:	1.0.1	Publisher Preferred Rates:
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), File Transfer (B14), Time Synchronization (B13), Unbuffered Reporting (B5)	Publisher Preferred Variants:
Certificate/Result Reviewer:	bruce.muschlitz,bruce.muschlitz	Subscriber Legacy Variants:
Approval Date:	10/24/2016	Subscriber Preferred Variants:
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1	Subscriber Preferred Rates:
Current Test Lab Name:	DNV Netherlands (A)	Product Variants:
Test Document:		Time Activated Control:
Description Migrated		

History

#1 - 07/09/2021 09:11 AM - Herbert Falk

- Umbrella Organization set to Schneider Electric

#2 - 07/11/2021 10:00 AM - Herbert Falk

This certificate and its information was migrated from a previous database

Files

16-2082_DNV_GL_Schneider_Electric-EcoSUI_ClientEd2_Certificate.pdf	9013 KB	07/08/2021	Herbert Falk
--	---------	------------	--------------