

IEC 61850 Certificate - IEC 61850 Certificate #3016

DS Agile C264 [GE Grid Solutions]

07/08/2021 06:07 PM - Herbert Falk

Status:	Approved	Test Document:	
Priority:	Normal	Certificate Name:	10016209-OPE/INC 16-2430
61850 Edition:	Edition 2	Certificate Hash:	F833E309A2ACCBA6D90EC76385E820 DF3E0320CC29F3FB1F7D45ED5B1FE 12F7E
61850 Tested Aspects:	Server	Vendor Artifact File Name:	
Company:	GE Grid Solutions	Vendor Artifact Hash:	
Address:	Parc Eurêka 81, rue Euclide – CS 11140 34060 Montpellier cedex 2 France	Umbrella Organization:	
Product:	DS Agile C264	Optional Reservation Test:	No
HW Version:	CPUv4	Serial Number:	
SW Version:	DS Agile V7	Publisher Legacy Variants:	
Key Words:	Protection	Publisher Preferred Rates:	
Test Procedure Version:	1.2.2	Publisher Preferred Variants:	
IEC 61850 Blocks Certified:	Basic Exchange (B1), Buffered Reporting (B6), Data Sets (B2), Direct Control (12a), Enhanced Direct Control (12c), Enhanced SBO Control (12d), File Transfer (B14), GOOSE Publish (9a), GOOSE Subscribe (9b), Substitution (B3), Time Synchronization (B13), Unbuffered Reporting (B5)	Subscriber Legacy Variants:	
Certificate/Result Reviewer:	bruce.muschlitz,bruce.muschlitz	Subscriber Preferred Variants:	
Approval Date:	11/25/2016	Subscriber Preferred Rates:	
Standards Tested:	61850-6, 61850-7-1, 61850-7-2, 61850-7-3, 61850-7-4, 61850-8-1		
Current Test Lab Name:	DNV Netherlands (A)		
Description			

History

#1 - 07/11/2021 09:59 AM - Herbert Falk

This certificate and its information was migrated from a previous database

Files

16-2430_DNVGL_GE_GRID_SOLUTIONS_DSAGILE_C264_ServerEOP_Certificate.pdf 07/08/2021

Herbert Falk